

Utility Earthquake Mitigation

Considerations
Requirements
Actions

Donald W. Shaw P.E.
National Earthquake Conference
April 13, 2012



Associated Electric Cooperative, Inc.

Impacts on Electricity Supply from the 2010 Chilean Earthquake

Araneda, Rudnick, Mocarquer and
Miquel
IEEE Powercon Oct 2010



Associated Electric Cooperative, Inc.

Chilean Codes include strict seismic standards (IEEE 693) for all electricity infrastructure


February 27, 2010 an 8.8 Richter scale earthquake hit the central part of Chile



Associated Electric Cooperative, Inc.

Electricity Supply Impacts Generation

- ▶ Immediate Loss of 4,522 MW
- ▶ 693 MW of Generation from 16 plants required extended time for repair (6.1% of total installed capacity)



Associated Electric Cooperative, Inc.

Electricity Supply Impacts

TRANSMISSION DAMAGES

	Number	Damaged	%
Substations	46	12	26%
Transmission lines (km.)	7280	1.6	0.02%



Associated Electric Cooperative, Inc.

Electricity Supply Impacts

Distribution



Associated Electric Cooperative, Inc.

Electricity Supply Impacts

Operations

- ▶ Communication systems severely impacted
- ▶ Ten year old SCADA system determined inadequate for the event
- ▶ Subsequent global blackout one week later caused by protection control cable damaged in the original quake



Associated Electric Cooperative, Inc.

New Madrid Power Plant




Associated Electric Cooperative, Inc.

New Madrid Plant Seismic Considerations

- ▶ Unit 1 was designed to conform to the 1967 – Uniform Building Code for a Zone 3 seismic area
- ▶ Unit 2 was designed to conform to the 1970 – Uniform Building Code for a Zone 3 seismic area
- ▶ Static design earthquake forces were determined in accordance with the Uniform Building Code for Zone 3



Associated Electric Cooperative, Inc.




Associated Electric Cooperative, Inc.



Earthquake Probabilities for New Madrid Seismic Zone

	Richter Scale	30 year Probability
Turbine Trip	6.3	90%
Turbine /Gen Damage	7.1	67%
Structural Damage	7.6	25%
Total Loss	8.3	3%



Associated Electric Cooperative, Inc.





Estimated AECl Long-Term Generation Loss Following Magnitude 7.0 Quake

Base Load Generation Loss New Madrid	1200 MW
Intermediate Generation Loss St Francis and Dell	1081 MW
Peaking Generation Loss Essex	107 MW
Total Generation Loss	2281 MW



Associated Electric Cooperative, Inc.

Seismic Design *Considerations* for Electric Facilities

- ▶ IEEE 693– Seismic Qualification Standard (69kV and above)
- ▶ ASCE Structure Design Guide (MOP 113)
- ▶ ASCE/SEI 7–10 for substation buildings



Associated Electric Cooperative, Inc.

Seismic Design *Requirements* for Electric Facilities

- ▶ Nuclear Regulatory Commission Approval
- ▶ Rural Utilities Service–Bulletin 1724E–300
- ▶ PUC– None
- ▶ Federal– None



Associated Electric Cooperative, Inc.

WHAT PREPARATIONS HAVE BEEN MADE?



Associated Electric Cooperative, Inc.



FEMA

National Level Exercise (NLE) 2011

AECI Facilities Involved with 2011 NLE

- New Madrid Plant
- St. Francis Plant
- Dell Plant
- Essex Plant
- Headquarters



Associated Electric Cooperative, Inc.



Satellite Communication Link



Associated Electric Cooperative, Inc.



AECI Earthquake Action Plan






**Dell Power Plant Fuel Oil,
Foundation Upgrade**










Future Transmission Line Design



Associated Electric Cooperative, Inc.

Future Substations Design



CONCLUSIONS

- ▶ Known impacts from prior events can guide preventive measures prioritization for Seismic Designs
- ▶ Design Requirements for Electric Facilities are essential to minimize expected earthquake impacts
- ▶ Critical Electric Grid facilities may in the future be subject to FERC earthquake measures (Currently do not exist)
- ▶ State Public Utility Commission (PUC) requirements may be implemented in the future



Associated Electric Cooperative, Inc.